



Kvalita pitné vody pro pásma se zdrojem: sm s Káraný+Podolí+Želivka
Za období: leden 2024 - erven 2024

| Parametr | Jednotka | Pr m r | Hygienický limit |
|---|------------|--------|--------------------------|
| Clostridium perfringens | KTJ/100ml | 0 | max.0 KTJ/100ml MH |
| Escherichia coli | KTJ/100ml | 0 | max.0 KTJ(MPN)/100ml NMH |
| intestinální enterokoky | KTJ/100ml | 0 | max.0 KTJ/100ml NMH |
| koliformní bakterie | KTJ/100ml | 0 | max.0 KTJ(MPN)/100ml MH |
| po ty kolonií p i 22°C | KTJ/ml | 1 | max.300 KTJ/ml MH |
| po ty kolonií p i 36°C | KTJ/ml | 0 | max.100 KTJ/ml MH |
| mikroskopický obraz - abioseston | % | 2 | max.5 % MH |
| mikroskopický obraz - po et organism | jedinci/ml | 0 | max.50 jedinci/ml MH |
| mikroskopický obraz - živé organismy | jedinci/ml | 0 | max.0 jedinci/ml MH |
| amonné ionty | mg/l | <0,03 | max.0,50 mg/l MH |
| barva | mg/l Pt | 3 | max.20 mg/l Pt MH |
| bromi nany | µg/l | 1,0 | max.10 µg/l NMH |
| dusi nany | mg/l | 26,9 | max.50 mg/l NMH |
| dusitany | mg/l | 0,01 | max.0,50 mg/l NMH |
| fluoridy | mg/l | 0,12 | max.1,5 mg/l NMH |
| ho ík | mg/l | 7,7 | 20 - 30 mg/l DH |
| chlor volný | mg/l | 0,12 | max.0,30 mg/l MH |
| chlore nany + chloritany (suma) | µg/l | 19,3 | max.250 µg/l NMH |
| chlore nany | µg/l | 19,3 | max.250 µg/l NMH |
| chloridy | mg/l | 28,7 | max.250 mg/l MH |
| chloritany | µg/l | <10,0 | max.250 µg/l NMH |
| chu | ° | 2 | max.2 ° MH |
| KNK 4.5 | mmol/l | 2,47 | |
| konduktivita | mS/m | 50,2 | max.125 mS/m MH |
| kyanidy celkové | mg/l | <0,010 | max.0,050 mg/l NMH |
| pach | ° | 2 | max.2 ° MH |
| pH - reakce vody | - | 7,44 | 6,5 - 9,5 - MH |
| sírany | mg/l | 71,3 | max.250 mg/l MH |
| suma pesticid. látek bez nerelevantních | ng/l | 19,7 | max.500 ng/l NMH |
| teplota vody | °C | 9,7 | 8,0 - 12,0 °C DH |
| TOC - celkový organický uhlík | mg/l | 2,04 | max.5,0 mg/l MH |
| vápník | mg/l | 70,7 | 40 - 80 mg/l DH |
| vápník a ho ík | mmol/l | 2,08 | 2 - 3,5 mmol/l DH |
| zákal | ZFn | 0,52 | max.5 ZFn MH |
| železo | mg/l | 0,03 | max.0,20 mg/l MH |

| Parametr | Jednotka | Pr m r | Hygienický limit |
|--|----------|----------|---------------------|
| antimon | mg/l | <0,0010 | max.0,01 mg/l NMH |
| arsen | mg/l | <0,0010 | max.0,01 mg/l NMH |
| beryllium | µg/l | <0,10 | max.2,0 µg/l NMH |
| bór | mg/l | <0,050 | max.1,5 mg/l NMH |
| draslík | mg/l | 3,4 | 1 - 10 mg/l DH |
| hliník | mg/l | 0,009 | max.0,20 mg/l MH |
| chrom | mg/l | <0,0010 | max.0,025 mg/l NMH |
| kadmium | mg/l | <0,00005 | max.0,0050 mg/l NMH |
| mangan | mg/l | 0,003 | max.0,050 mg/l MH |
| m | mg/l | <0,005 | max.1 mg/l NMH |
| nikl | mg/l | 0,0010 | max.0,02 mg/l NMH |
| olovo | mg/l | <0,0010 | max.0,01 mg/l NMH |
| rtu | mg/l | <0,0002 | max.0,001 mg/l NMH |
| selen | mg/l | 0,0010 | max.0,02 mg/l NMH |
| sodík | mg/l | 13,5 | max.200 mg/l MH |
| st íbro | mg/l | 0,0010 | max.0,025 mg/l NMH |
| 2,4 D (2,4-dichlorfenoxyoctová kyselina) | ng/l | <10,0 | max.100 ng/l NMH |
| 2,4-DP (dichlorprop) | ng/l | <20,0 | max.100 ng/l NMH |
| 2,6-dichlorobenzamid | ng/l | 10,7 | max.3000 ng/l NMH |
| acetamiprid | ng/l | <10,0 | max.100 ng/l NMH |
| acetochlor | ng/l | <10,0 | max.100 ng/l NMH |
| acetochlor ESA | ng/l | <20,0 | max.100 ng/l NMH |
| acetochlor OA | ng/l | <20,0 | max.100 ng/l NMH |
| aclonifen | ng/l | <20,0 | max.100 ng/l NMH |
| alachlor | ng/l | 10,4 | max.100 ng/l NMH |
| alachlor ESA | ng/l | 33,1 | max.1000 ng/l NMH |
| alachlor OA | ng/l | <20,0 | max.1000 ng/l NMH |
| atrazin | ng/l | 10,0 | max.100 ng/l NMH |
| atrazin desethyl desisopropyl | ng/l | 10,4 | max.100 ng/l NMH |
| atrazin-desethyl | ng/l | <10,0 | max.100 ng/l NMH |
| atrazine desisopropyl | ng/l | <10,0 | max.100 ng/l NMH |
| atrazine-2-hydroxy | ng/l | <10,0 | max.2000 ng/l NMH |
| azoxystrobin | ng/l | <10,0 | max.100 ng/l NMH |
| bentazon | ng/l | <10,0 | max.100 ng/l NMH |
| 1-H-Benzotriazol | ng/l | 34,0 | max.4000 ng/l NMH |
| 1-methyl-1-H-Benzotriazol | ng/l | <20,0 | |
| 5-methyl-1-H-Benzotriazol | ng/l | <20,0 | max.4000 ng/l NMH |
| bifenox | ng/l | <50,0 | max.100 ng/l NMH |
| bisfenol-A | ng/l | <50,0 | max.2500 ng/l NMH |
| bisfenol-B | ng/l | <50,0 | |
| bisfenol-S | ng/l | <50,0 | |
| Butachlor ESA | ng/l | <20,0 | max.100 ng/l NMH |
| Butachlor OA | ng/l | <20,0 | max.100 ng/l NMH |
| carbendazim | ng/l | <10,0 | max.100 ng/l NMH |

| Parametr | Jednotka | Pr m r | Hygienický limit |
|-------------------------------|----------|--------|--------------------|
| clomazone | ng/l | <10,0 | max.100 ng/l NMH |
| clopyralid | ng/l | <10,0 | max.100 ng/l NMH |
| clothianidin | ng/l | <10,0 | max.100 ng/l NMH |
| cyanazin | ng/l | <10,0 | max.100 ng/l NMH |
| cyprokonazol | ng/l | <10,0 | max.100 ng/l NMH |
| cyprosulfamide | ng/l | <10,0 | max.100 ng/l NMH |
| DEET - diethyltoluamide | ng/l | <50,0 | max.100 ng/l NMH |
| desmetryn | ng/l | <10,0 | max.100 ng/l NMH |
| diazinon | ng/l | <10,0 | max.100 ng/l NMH |
| difenoconazole | ng/l | <10,0 | max.100 ng/l NMH |
| diflufenican | ng/l | <10,0 | max.100 ng/l NMH |
| dichlorvos | ng/l | <50,0 | max.100 ng/l NMH |
| dimethachlor | ng/l | <10,0 | max.100 ng/l NMH |
| dimethachlor CGA 369873 | ng/l | 50,3 | max.6000 ng/l NMH |
| dimethachlor ESA | ng/l | 20,4 | max.6000 ng/l NMH |
| dimethachlor OA | ng/l | <20,0 | max.6000 ng/l NMH |
| Dimethachlor - suma metabolit | ng/l | 52,0 | max.12000 ng/l NMH |
| dimethenamid | ng/l | <10,0 | max.100 ng/l NMH |
| dimethenamid ESA | ng/l | <20,0 | max.100 ng/l NMH |
| dimethenamid OA | ng/l | <20,0 | max.100 ng/l NMH |
| dimethoate | ng/l | <10,0 | max.100 ng/l NMH |
| Dimethomorph | ng/l | <10,0 | max.100 ng/l NMH |
| diuron | ng/l | <10,0 | max.100 ng/l NMH |
| epoxiconazol | ng/l | <10,0 | max.100 ng/l NMH |
| ethofumesate | ng/l | <10,0 | max.100 ng/l NMH |
| fenitrothion | ng/l | <100,0 | max.100 ng/l NMH |
| fenpropidin | ng/l | <20,0 | max.100 ng/l NMH |
| fenpropimorph | ng/l | <20,0 | max.100 ng/l NMH |
| fenthion | ng/l | <10,0 | max.100 ng/l NMH |
| fluazinam | ng/l | <10,0 | max.100 ng/l NMH |
| Flufenacet | ng/l | 10,0 | max.100 ng/l NMH |
| flufenacet ESA | ng/l | 20,9 | max.100 ng/l NMH |
| flufenacet OA | ng/l | <20,0 | max.100 ng/l NMH |
| fluopicolide | ng/l | <10,0 | max.100 ng/l NMH |
| fluroxypyr | ng/l | <10,0 | max.100 ng/l NMH |
| hexazinon | ng/l | 11,5 | max.100 ng/l NMH |
| chlorfenvinphos | ng/l | <10,0 | max.100 ng/l NMH |
| chloridazon | ng/l | <10,0 | max.100 ng/l NMH |
| chloridazon - suma metabolit | ng/l | 620,9 | max.6000 ng/l NMH |
| chloridazon-desphenyl | ng/l | 436,2 | max.3000 ng/l SH |
| chloridazon-methyl-desphenyl | ng/l | 185,4 | max.3000 ng/l SH |
| chlorotoluron | ng/l | <10,0 | max.100 ng/l NMH |
| chlorotoluron desmethyl | ng/l | <10,0 | max.100 ng/l NMH |
| chlorpyriphos | ng/l | <10,0 | max.100 ng/l NMH |

| Parametr | Jednotka | Pr m r | Hygienický limit |
|---|----------|--------|-------------------|
| chlorsulfuron | ng/l | <20,0 | max.100 ng/l NMH |
| imazalil | ng/l | <20,0 | max.100 ng/l NMH |
| imidacloprid | ng/l | 11,7 | max.100 ng/l NMH |
| irgarol (cybutrine) | ng/l | <10,0 | max.100 ng/l NMH |
| isoproturon | ng/l | <10,0 | max.100 ng/l NMH |
| isoproturon-monodesmethyl | ng/l | <10,0 | max.100 ng/l NMH |
| Isoxaflutol benzoic acid | ng/l | <10,0 | max.100 ng/l NMH |
| Isoxaflutol diketonitril | ng/l | <10,0 | max.100 ng/l NMH |
| isoxaflutole | ng/l | <10,0 | max.100 ng/l NMH |
| linuron | ng/l | <10,0 | max.100 ng/l NMH |
| MCPA | ng/l | <20,0 | max.100 ng/l NMH |
| MCPB | ng/l | <20,0 | max.100 ng/l NMH |
| MCPP (mecoprop) | ng/l | <10,0 | max.100 ng/l NMH |
| mesotrione | ng/l | <10,0 | max.100 ng/l NMH |
| metalaxyl | ng/l | <10,0 | max.100 ng/l NMH |
| metamitron | ng/l | <10,0 | max.100 ng/l NMH |
| metazachlor | ng/l | 11,1 | max.100 ng/l NMH |
| metazachlor ESA | ng/l | 178,8 | max.5000 ng/l NMH |
| metazachlor OA | ng/l | 65,1 | max.5000 ng/l NMH |
| metformin | ng/l | 177,4 | max.1000 ng/l MH |
| methiocarb | ng/l | <10,0 | max.100 ng/l NMH |
| metolachlor ESA | ng/l | 76,1 | max.6000 ng/l NMH |
| metolachlor OA | ng/l | 22,9 | max.6000 ng/l NMH |
| metolachlor (izomery) | ng/l | 10,0 | max.100 ng/l NMH |
| metribuzin | ng/l | <10,0 | max.100 ng/l NMH |
| metribuzin desamino | ng/l | <10,0 | max.100 ng/l NMH |
| Metribuzin desaminodiketo (DADK) | ng/l | <100,0 | max.100 ng/l NMH |
| 2-amino-4-methoxy-6-methyl-1,3,5-triazi | ng/l | <20,0 | max.100 ng/l NMH |
| nicosulfuron | ng/l | <10,0 | max.100 ng/l NMH |
| oxadiazon | ng/l | <10,0 | max.100 ng/l NMH |
| pendimethalin | ng/l | <20,0 | max.100 ng/l NMH |
| pethoxamid | ng/l | <10,0 | max.100 ng/l NMH |
| pethoxamid ESA | ng/l | 20,7 | max.100 ng/l NMH |
| PFOA (perfluoroktanová kyselina) | ng/l | <10,0 | |
| PFOS (perfluoroktansulfonová kyselina) | ng/l | <10,0 | |
| prochloraz | ng/l | <10,0 | max.100 ng/l NMH |
| prometryn | ng/l | <10,0 | max.100 ng/l NMH |
| propachlor | ng/l | <10,0 | max.100 ng/l NMH |
| Propachlor ESA | ng/l | <20,0 | max.100 ng/l NMH |
| Propachlor OA | ng/l | <20,0 | max.100 ng/l NMH |
| Propamocarb | ng/l | <10,0 | max.100 ng/l NMH |
| propazin | ng/l | <10,0 | max.100 ng/l NMH |
| propiconazol | ng/l | <10,0 | max.100 ng/l NMH |
| Prosulfocarb | ng/l | <10,0 | max.100 ng/l NMH |

| Parametr | Jednotka | Pr m r | Hygienický limit |
|----------------------------------|----------|--------|------------------|
| quinoxyfen (chinoxyfen) | ng/l | <10,0 | max.100 ng/l NMH |
| simazin | ng/l | <10,0 | max.100 ng/l NMH |
| tebuconazol | ng/l | <10,0 | max.100 ng/l NMH |
| terbuthylazin | ng/l | <10,0 | max.100 ng/l NMH |
| terbuthylazin-desethyl-2-hydroxy | ng/l | <10,0 | max.100 ng/l NMH |
| terbutryn | ng/l | <10,0 | max.100 ng/l NMH |
| terbutylazin-2-hydroxy | ng/l | 10,3 | max.100 ng/l NMH |
| terbuthylazin-desethyl | ng/l | <10,0 | max.100 ng/l NMH |
| thiacloprid | ng/l | <10,0 | max.100 ng/l NMH |
| thiamethoxam | ng/l | <10,0 | max.100 ng/l NMH |
| Thiencarbazone-methyl | ng/l | <20,0 | max.100 ng/l NMH |
| tri-allate | ng/l | <20,0 | max.100 ng/l NMH |
| trinexapac-ethyl | ng/l | <10,0 | max.100 ng/l NMH |
| Tritosulfuron | ng/l | <20,0 | max.100 ng/l NMH |
| 1,1,2,2-tetrachlorethen | µg/l | <0,10 | max.10 µg/l NMH |
| 1,1,2-trichlorethen | µg/l | <0,10 | max.10 µg/l NMH |
| 1,1-dichlorethen | µg/l | <0,10 | |
| 1,2-dichlorethan | µg/l | <0,10 | max.3 µg/l NMH |
| 1,2-dichlorethen | µg/l | 0 | |
| benzen | µg/l | <0,10 | max.1 µg/l NMH |
| bromdichlormethan | µg/l | 3,58 | |
| bromoform | µg/l | 0,48 | |
| cis-1,2-dichlorethen | µg/l | <0,10 | |
| dibromchlormethan | µg/l | 2,34 | |
| dichlormethan | µg/l | <0,10 | |
| ethylbenzen | µg/l | <0,10 | |
| chlorbenzen | µg/l | <0,10 | |
| chloroform | µg/l | 6,4 | max.30 µg/l MH |
| m- +p-xylen | µg/l | <0,10 | |
| o+m+p-xylen | µg/l | 0 | |
| o-xylen | µg/l | <0,10 | |
| styren | µg/l | <0,10 | |
| tetrachlormethan | µg/l | <0,10 | |
| toluen | µg/l | <0,10 | |
| trans-1,2-dichlorethen | µg/l | <0,10 | |
| trihalomethany | µg/l | 12,76 | max.50 µg/l NMH |
| vinylchlorid | µg/l | <0,1 | max.0,5 µg/l NMH |
| benzo(g,h,i)perylen | ng/l | <0,5 | |
| benzo(a)pyren | ng/l | <0,5 | max.10 ng/l NMH |
| benzo(b)fluoranten | ng/l | <0,5 | |
| benzo(k)fluoranten | ng/l | <0,5 | |
| fluoranten | ng/l | 2,0 | |
| indeno(1,2,3cd)pyren | ng/l | <0,5 | |
| suma PAU(4) | ng/l | 0 | max.100 ng/l NMH |

| Parametr | Jednotka | Pr m r | Hygienický limit |
|--------------------------------------|----------|--------|--------------------|
| aldrin | ng/l | <3,0 | max.30 ng/l NMH |
| dieldrin | ng/l | <3,0 | max.30 ng/l NMH |
| heptachlor | ng/l | <3,0 | max.30 ng/l NMH |
| heptachlorepoxid | ng/l | <3,0 | max.30 ng/l NMH |
| hexachlorbenzen | ng/l | <3,0 | max.100 ng/l NMH |
| lindan | ng/l | <3,0 | max.100 ng/l NMH |
| methoxychlor | ng/l | <5,0 | max.100 ng/l NMH |
| p,p'-DDE | ng/l | <3,0 | max.100 ng/l NMH |
| p,p'-DDT | ng/l | <3,0 | max.100 ng/l NMH |
| AMPA (aminomethylfosfonová kyselina) | ng/l | <50,0 | max.100 ng/l NMH |
| glyfosát (N-(fosfonomethyl)glycin) | ng/l | <50,0 | max.100 ng/l NMH |
| uran | mg/l | 0,0010 | max.0,015 mg/l NMH |

Legenda:

Hodnoty uvedené se znaménkem mén než (<) jsou hodnoty pod mezí stanovitelnosti použité analytické metody.

Výpočet pro použití mezí stanovitelnosti:

V případě, že ve výpočtu pro měření figuruje mezí stanovitelnosti, je do výpočtu brána polovina meze stanovitelnosti.

Typ limitu:

DH - doporučená hodnota, MH - mezní hodnota, NMH - nejvyšší mezní hodnota, SH - směrná hodnota

Hygienické limity odpovídají limitům uvedeným ve vyhlášce MZK č. 252/2004 Sb. (Příloha č. 1) a limitním hodnotám uvedeným v Seznamu posouzených nerelevantních metabolitů pesticidů MZK R.

Mezní hodnota pro pražskou distribuci:

Hygienickou stanicí hl. města Prahy je pro pražskou distribuci stanovena mezní hodnota

pro ukazatel počet kolonií při 22 °C (300 KTJ/ml MH) a pro ukazatel počet kolonií při 36 °C (100 KTJ/ml MH), která není daná vyhl. č. 252/2004 Sb., v platném znění.

Pro ukazatel metformin je Hygienickou stanicí hl. města Prahy pro pražskou distribuci stanoven nižší hygienický limit (1000 ng/l MH), který je odlišný od limitu daného vyhl. č. 252/2004 Sb., v platném znění.

Procenta a jednotky:

1 ng/l = 0,001 µg/l = 0,000001 mg/l

Údaje o kvalitě vody reprezentují průměry za danou oblast. U směsí se lokálně může poměr jednotlivých zdrojů lišit.